



# UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard  
Orlando, FL 32811  
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.36448

## Inspection Report

Project Name: 2202 Venetian Avenue ~ COBI  
Address: 2202 Venetian Avenue ~ COBI ,Belle Isle, Orange  
County, FL  
Client: City of Belle Isle  
ProjectNo.: 0115.1400125.0000

Date: 04/11/2014 Any any  
Permit No.: 2014-04-014  
Lot No.:  
Contact: Mark Witt at 407 744 1953

Scope of Inspection: FINAL gas permit

**Inspection Type:** See Scope

**Disposition of Inspection:** Pass

### Comments:

04/13/2014 rough gas pipe PSI test was good at 15 psi all pipe connected to equipment.

Luis Colon

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Luis Colon, BN3362