



UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard
Orlando, FL 32811
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.36042

Inspection Report

Project Name: 2819 Nela Avenue - COBI
Address: 2819 Nela Avenue - COBI ,Belle Isle, Orange
County, FL 32812
Client: City of Belle Isle
ProjectNo.: 0115.1300549.0000

Date: 04/01/2014 Any any
Permit No.: 2013-05-083
Lot No.:
Contact: Samuel at 407 833 9708

Scope of Inspection: FINAL electrical inspection. PLESE CALL 1 HR IN ADVANCE TO BE MET AT SITE.

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

04/01/2014 Contractor not on site. A call was placed but his phone number came up "disconnected". Final Electrical Failed: label electrical panel; add GFI service outlet within 25' of HVAC condenser (this was requested during rough inspections); install missing cover plates throughout. Angel Perez

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Angel Perez, BN 5240