



UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard
Orlando, FL 32811
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.36045

Inspection Report

Project Name: 3307 Trentwood Blvd - COBI

Date: 04/01/2014 Any am

Address: 3307 Trentwood Blvd - COBI ,Belle Isle, Orange

Permit No.: 2014-03-013

Client: ^{County, FL}
City of Belle Isle

Lot No.:

ProjectNo.: 0115.1300688.0000

Contact: Stephen Edwards at 407-489-6817

Scope of Inspection: FINAL shed inspection

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

04/01/2014 Final Inspection FAILED: anchoring system was not done per plans at 24"OC. Homeowner and contractor were notified.

Angel Perez

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Angel Perez, BN 5240