



UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard
Orlando, FL 32811
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.36805

Inspection Report

Project Name: 4426 Hoffner Avenue ~ COBI
Address: 4426 Hoffner Avenue ~ COBI ,Belle Isle, Orange
Client: ^{County, FL} City of Belle Isle
ProjectNo.: 0115.1400167.0000

Date: 04/29/2014 Any any
Permit No.: 2014-04-012
Lot No.:
Contact: Z Develpment Services/Susan Manches at 4

Scope of Inspection: REVIEW new plans dropped off per request for Wendy's Parking Lot

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

- | | | |
|------------|--|-------------|
| 04/29/2014 | (a) Provide the correct windload design VULT 140 mph on plans (not 130-140)per 2010 FBC 1609A; | Angel Perez |
| | (b) Provide the EXPOSURE Category, per 2010 FBC 1609.4; | |
| | (c) Correct the undersized plumbing vent shown as 1/2" on the isometric drawing to meet current sizes as indicated on your vent chart, per 2010 FPC 916. | |

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Angel Perez, BN 5240