



UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard
Orlando, FL 32811
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.36384

Inspection Report

Project Name: 6109 Matchett Road ~ COBI

Date: 04/09/2014 Any any

Address: 6109 Matchett Road ~ COBI ,Belle Isle, Orange

Permit No.: 2014-02-026

Client: ^{County, FL}
City of Belle Isle

Lot No.:

ProjectNo.: 0115.1300683.0000

Contact: Kathy Rendell at 407 856 7770

Scope of Inspection: Final Gas inspection

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

04/09/2014 Gas rough required; gas pressure gauge on zero - 15 PSI required per fuel gas code.

Luis Colon

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Luis Colon, BN3362