



UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard
Orlando, FL 32811
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.36092

Inspection Report

Project Name: 7236 Seminole Drive ~ COBI

Date: 04/03/2014 Any any

Address: 7236 Seminole Drive ~ COBI ,Belle Isle, Orange

Permit No.: 2014-03-034

Client: ^{County, FL}
City of Belle Isle

Lot No.:

ProjectNo.: 0115.1400150.0000

Contact: Collina Gast at 407-581-8161

Scope of Inspection: REVIEW garage extension permit app ~ approved by Zoning

Inspection Type: See Scope

Disposition of Inspection: Complete

Comments:

04/03/2014 Incorrect wind exposure category "B". Update truss and construction plans to category "D".

Angel Perez

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Angel Perez, BN 5240