



UNIVERSAL ENGINEERING SCIENCES

Consultants In: Geotechnical Engineering • Environmental Sciences
Geophysical Services • Materials Testing • Threshold Inspection
Building Code Administration, Compliance Inspection & Plan Review

3532 Maggie Blvd, Orlando, FL 32811 - P: 407.423.0504 - F: 407.423.3106

Work Order No. 80624

Inspection Report

Project Name: 1407 Nevada Avenue ~ COBI

Address: 1407 Nevada Avenue ~ COBI, Belle Isle, Orange County, FL

Client: City of Belle Isle

ProjectNo.: 0115.1400152.0000-0115-02

Scope of Inspection: Rough Plumbing Inspection

Inspection Type: See Scope

Date: 04/20/2017 Any any

Permit No: 2017-04-048

Lot No.:

Contact: Ivelinda Diaz at 407 282-2900

Disposition of Inspection: Fail

Comments:

<u>Task Date</u>	<u>Task Note</u>	<u>User Name</u>
04/21/2017	Per Les: no water in stack; leak may be in building drain in right rear room. FBC R P2503.4 AND 2503.5	Collina Gast

I hereby affirm that to the best of my knowledge and belief, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector: Les Rutherford, BN 4564