



UNIVERSAL ENGINEERING SCIENCES

Consultants In: Geotechnical Engineering • Environmental Sciences
Geophysical Services • Materials Testing • Threshold Inspection
Building Code Administration, Compliance Inspection & Plan Review

3532 Maggie Blvd, Orlando, FL 32811 - P: 407.423.0504 - F: 407.423.3106

Work Order No. 79837

Inspection Report

Project Name: 4400 Hoffner Avenue ~ COBI commercial Old Winn
Dixie Bldg

Date: 04/04/2017 Any any

Address: 4400 Hoffner Avenue ~ COBI commercial, Belle Isle, Orange
County, FL

Permit No: 2017-03-081

Client: City of Belle Isle

Lot No.:

ProjectNo.: 0115.1500631.0000-0115-09

Contact: Susan Manchester at 407 581
8161

Scope of Inspection: REVIEW building permit app for fuel system including underground storage tanks, fuel piping,
dispensers, switches, monitors & controls.

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

<u>Task Date</u>	<u>Task Note</u>	<u>User Name</u>
04/04/2017	PER JOE: COULD NOT APPROVE AS THE ELECTRICAL INFORMATION WAS NOT PROVIDED. PROVIDE COMPLETE ELECTRICAL INFORMATION FOR THE ELECTRICAL SUPPLY, EMERGENCY SHUT OFF AND GENERATOR INFORMATION, IF APPLICABLE, FOR REVIEW.	Collina Gast

I hereby affirm that to the best of my knowledge and belief, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector: Joseph Crum, BU 540