

UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maggie Boulevard Orlando, FL 32811

Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.41302

Inspection Report

Project Name: 5126 S Conway Rd All 4 Pets	Date: 08/26/2014 Any any
Address: 1600 Nela Avenue ,Belle Isle, Orange County, FL	Permit No.:
Client: City of Belle Isle	Lot No.:
ProjectNo.: 0115.1100061.0000	Contact: Jeff and Jane Lauzon at 407-694-6438
Scope of Inspection: Annual Fire Safety Inspection for new business	

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

08/27/2014

1.Florida Fire Prevention Code NFPA 101 39.3.5 Portable fire extinguishers shall be provided in every business occupancy in accordance with 9.7.4.1. No fire extinguisher

Lisa Whaley

2.Florida Fire Prevention Code 101 7.8.1.2 Illumination of means of egress shall be continuous during the

time that the conditions of occupancy require that the means of egress be available for use. Emergency

light over the front door was not working with battery backup.

3.Florida Fire Prevention Code 101 7.10.5.1 Every sign required by 7.10.1.2, 7.10.1.5, or 7.10.8.1, other than

where operations or processes require low lighting levels, shall be suitable illuminated by a reliable light

source. Externally and internally illuminated signs shall be legible in both the normal and emergency

lighting mode. Exit signs were not working with battery backup.

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector: Lisa Whaley,

Lisa Wholey