



UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard
Orlando, FL 32811
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.40973

Inspection Report

Project Name: 5124 S Conway Road - COBI

Date: 08/20/2014 Any am

Address: 5124 S Conway Road ,Belle Isle, Orange County,

Permit No.: 2014-08-066

Client: City of Belle Isle

Lot No.:

ProjectNo.: 0115.1300216.0000

Contact: Bill Bailes at 407 486 8899

Scope of Inspection: Rough electrical inspection

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

08/20/2014 Recepticals added to one side of fire rated walls. Unknown penetrations on other retail occupied space. Need Putty patches for all receptical penetrations.

Donald Beckman

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Donald Beckman, BN5123