



UNIVERSAL ENGINEERING SCIENCES, INC.

3532 Maqqie Boulevard
Orlando, FL 32811
Phone: 407-581-8161 Fax: 407-581-0313

Work Order No.40463

Inspection Report

Project Name: 6303 Matchett Road ~ COBI
Address: 6303 Matchett Road ~ COBI ,Belle Isle, Orange
County, FL
Client: City of Belle Isle
ProjectNo.: 0115.1400375.0000

Date: 08/07/2014 Any am
Permit No.: 2014-07-040
Lot No.:
Contact: Stepanie Crew at 850 264 7852

Scope of Inspection: Rough plumbing inspection

Inspection Type: See Scope

Disposition of Inspection: Fail

Comments:

08/08/2014 Drainage tee at Bathroom lavatory has been reduced in the direction of flow. FAILED

Angel Perez

I hereby affirm that to the best of my knowledge and believe, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector : Angel Perez, BN 5240