



UNIVERSAL ENGINEERING SCIENCES

Consultants In: Geotechnical Engineering • Environmental Sciences
Geophysical Services • Materials Testing • Threshold Inspection
Building Code Administration, Compliance Inspection & Plan Review

3532 Maggie Blvd, Orlando, FL 32811 - P: 407.423.0504 - F: 407.423.3106

Work Order No. 70854

Inspection Report

Project Name: 3520 Country Lakes Drive ~ COBI	Date: 08/12/2016 Any am
Address: 3520 Country Lakes Drive ~ COBI, Belle Isle, Orange County, FL	Permit No: 2016-05-035
Client: City of Belle Isle	Lot No.:
ProjectNo.: 0115.1600268.0000-0115-05	Contact: Gregg Necrason at 407 758-5889
Scope of Inspection: Final Plumbing Inspection	
Inspection Type: See Scope	

Disposition of Inspection: Fail

Comments:

<u>Task Date</u>	<u>Task Note</u>	<u>User Name</u>
08/12/2016	Plumbing Final - Failed FBC-P 304.4 and FBC-R P2606.1 require that all pipe penetrations through walls be sealed. The master bath and the laundry sink have water and sanitary pipes penetrating the walls that are not sealed.	David Young

I hereby affirm that to the best of my knowledge and belief, the above listed inspection was performed as indicated and the work was reviewed for compliance with the approved plans, and all pertinent sections of the Florida Building Code.

Inspector: David Young, BN466